



Wastewater Treatment Utility
 500 South River Road
 West Lafayette, Indiana 47906
 Voice: (765) 775-5145
 Fax: (765) 775-5149

MONTHLY REPORT OF OPERATIONS

National Pollutant Discharge Elimination System -- NPDES

October 2011--MONTHLY AVERAGES

Limit

TSS	4	mg/l	(30.00)
CBOD	2.5	mg/l	(25.00)
NH ₄	0.13	mg/L	(6.00)
Cl ₂	0.02	mg/L	(0.06)
E. COLI	19	#/100ml	(125.00)
FLOW TOTAL	232.32	MG	
	AVG	7.49	MGD
	MAX	13.99	MGD
	MIN	5.61	MGD
PRECIPITATION	2.87	INCHES	

October 2011--PERCENT REMOVALS

TSS	97.4	REPORT ONLY
CBOD	98.3	REPORT ONLY

COMBINED SEWER OVERFLOWS

October 2011	MG	HOURS	Events
TOTAL FLOW	232.33		
PERCENT TREATED	99.996		
OVERFLOW POINT			
DEHART STREET	0.0090	11.76	3
QUINCY STREET	0.0010	2.75	3
OVERFLOW TOTAL	0.0100	14.51	6